

# Certificate of Compliance



No. OP200106.SME0082

Technical Construction File no. TESH19123021464, TESH19123021465

Certificate's  
Holder:

Certification ECM  
Mark:



Product: RCCB  
 Model(s): EWP-80A, EWP-80AC, EWP-80B, EWP-100B (see  
 Rating: the following annex I)

Verification to: Standard:  
 IEC 61008-1:2010,  
 EN 61008-1:2012+A12:2017,  
 IEC 62423:2009, EN 62423:2012,  
 IEC 61543:1995+A2:2005,  
 EN 61543:1995+A2:2006

related to CE Directive(s):  
 2014/35/EU (Low Voltage)  
 2014/30/EU (Electromagnetic Compatibility)

**Remark:** The product(s) has been verified on a voluntary basis. The product(s) satisfies the requirements of the Certification Mark of ECM, in reference to the above listed Standard(s). The above Compliance Mark can be affixed on the product(s) accordingly to the ECM regulation about its release and its use. The regulation can be found at [www.entecerma.it](http://www.entecerma.it). This Certificate of Compliance can be checked for validity at [www.entecerma.it](http://www.entecerma.it)

This verification doesn't imply assessment of the production of the product(s).

Additional information, clarification about the **CE** Marking:



We attest that a TCF for the **CE** Marking process is in place. Whereas the Manufacturer is Responsible to start the **CE Marking Certification Procedure** and to perform all the necessary activities, as required by the Directive before placing the **CE** Mark on the product(s).

Date of issue 07 January 2020

Expiry date 06 January 2025

Chief Manager  
 Marco Morino

Deputy Manager  
 Amanda Payne

**Ente Certificazione Macchine Srl**

Via Ca' Bella, 243 – Loc. Castello di Serravalle – 40053 Valsamoggia (BO) - ITALY

☎ +39 051 6705141 📠 +39 051 6705156 ✉ info@entecerma.it 🌐 www.entecerma.it

# Annex I



No. OP200106.SME0082

Technical Construction File no. TLSH19123021464, TESH19123021465

## Rating:

2Pole: 230V/240V (1P+N) 4Pole: 400V/415V (3P+N)

16A, 25A, 32A, 40A, 50A, 63A, 80A, 100A

50/60Hz 30mA, 100mA, 300mA / Type B, Type A, Type AC

$I_m = I_{\Delta m} = 500$  or  $10I_n$ ,  $I_{\Delta c} = I_{nc} = 10000A$

